

| <i>Catalogue number</i> | <i>Series ¹</i> | <i>Description</i> | <i>Directive ²</i> | | |
|-------------------------|----------------------------|---|-------------------------------|------------|-------------|
| | | | <i>EMC</i> | <i>LVD</i> | <i>RoHS</i> |
| 700 – E * * * * | | <i>IEC Contactor Relays per Nomenclature</i> | Yes | Yes | Yes |
| 700S – E * * * * | | <i>IEC Safety Contactor Relays per Nomenclature</i> | | | |

- 1) *Products of the series level indicated, as well as succeeding series levels, are certified. If no series number is given, then all series are certified.*
- 2) *Yes = Product is certified to this directive.*

MODEL NOMENCLATURE:

***IEC Contactor Relays and IEC Safety Contactor Relays
Catalogue Number Explanation***

| | | | | |
|-----------------|----------|------------|-----------|----------|
| 700S – E | F | 440 | KJ | C |
| 1 | 2 | 3 | 4 | 5 |

| Position | Catalogue No. Suffix | Options/Descriptions |
|-----------------|---|--|
| <i>1</i> | <i>700 – E</i> <i>700S – E</i> | <i>Base Catalogue Number</i> <i>IEC Contactor Relay</i> <i>IEC Safety Contactor Relay</i> |
| <i>2</i> | <i>F</i> | <i>Terminal Type</i> <i>Screw terminal</i> |
| <i>3</i> | <i>220, 310, 400</i> <i>440, 530, 620</i> | <i>Contact Configuration</i> <i>Contact configuration of contactor relay</i> <i>Contact configuration of safety contactor relay</i> |
| <i>4</i> | <i>KJ</i> <i>KY</i> <i>KD</i> <i>KN</i> <i>EQ</i> <i>EJ</i> <i>QJ</i> | <i>Coil Control Voltage Code</i> <i>24...60 VAC / 20...60 VDC</i> <i>48...130 VAC/VDC</i> <i>100...250 VAC/VDC</i> <i>250...500 VAC/VDC</i> <i>12...20 VDC, low power consumption</i> <i>24...60 VAC / 20...60 VDC, low power consumption</i> <i>24 VDC, low power consumption, fast drop-out</i> |
| <i>5</i> | <i>Blank</i> <i>C</i> | <i>Contacts</i> <i>No contact block provided (700 – E)</i> <i>Contact block permanently fixed (700S – E)</i> |